

Fire Department Requirements

Hayday Grass Drag Races

Vendors:

- Tents exceeding 299 sq. ft. must have a minimum of 2 exits. Exits must be a minimum of 72" wide.
- Exits must remain open or may be covered with a curtain, provided the curtain is free sliding and of a contrasting color.
- Exits shall be clearly marked.
- No Smoking allowed in tents. Must have signs posted.
- All open flames, combustible liquids, gas or charcoal cooking devices are not permitted inside the tents. These items must be kept a minimum of 20' from the tent.
- All tents shall have a fire extinguisher (minimum size 2A 10BC).

Racers:

- All racers are to have a fire extinguisher (minimum size 2A 10BC) located in or near their race trailer.

Pit Area:

- Pit area and starting line shall have fire extinguishers (minimum size 20A 80BC) located no greater than 50' away from any area.

Racing Fuel Vendor:

- Positive displacement pumps shall be used while dispensing fuel from storage containers
- The fuel drums shall be placed on the ground and grounded with ground cable, bond wire, etc. to prevent sparking
- Fire extinguisher (minimum size 20A 80BC) shall be located at the fuel site.

Almelund Fire & Rescue
15740 Maple Lane
Almelund, MN 55012
Fire Chief - Larry Ferrier
Telephone: 651-583-3473